



**„БУЛАКВА СТАНДАРТ“ ЕООД**  
ОРГАН ЗА СЕРТИФИКАЦИЯ НА СТРОИТЕЛНИ ПРОДУКТИ  
„ЗНАК ЗА КАЧЕСТВО НА БАВ“

София 1046, бул. Христо Смирненски 1, УАСГ - Ректорат, ст. 115  
моб.: 0879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)

F 7.0-14, v.1.1

# C E R T I F I C A T E

FOR  
„QUALITY MARK OF BWA“

TO PIPELIFE BULGARIA EOOD  
FOR

Plastic pipes for water supply, and for drains and sewers under pressure from  
polyethylene (PE100RC)

Produced in: PIPELIFE BULGARIA EOOD, 3 Industrialna Str.,  
2140 Botevgrad, Bulgaria

Released on the market by: PIPELIFE BULGARIA EOOD, 3 Industrialna Str.,  
2140 Botevgrad, Bulgaria

The Certification Body for Construction Products “Quality Mark of BWA” (CBCP) to  
“BULAQUA Standart” LTD verifies that the construction products, described in the present  
certificate are assessed and conform to the requirements of Scheme A – Voluntary certification  
according to the following international standards:

**BDS EN 12201-1:2024, BDS EN 12201-2:2024, SD CEN/TS 12201-7:2014**

According to Decision № PL-053-150/12.02.2026

Date of initial issuance: 10.06.2014

Date of issuance: 12.02.2026

Validity: 31.01.2027

**CERTIFICATE № PL-053-085/12.02.2026**

Signature:

Director of CBCP

/Dipl. Ing. Alexander Marinchev/



*The validity of the certificate is 3 years and is annually re-issued after control check (audit) when there is determined conformity with the characteristics of the product and the conditions of the production or of the production control are not essentially altered. This certificate includes 2 annexes of 3 pages, which are an integral part of the same.*

*CBCP to “BULAQUA Standart” LTD is accredited with Accreditation certificate, reg. № 7 OCII/ 29.04.2025, valid until 22.12.2027, published by Executive Agency “Bulgarian Accreditation Service”, according to the requirements of standard BDS EN ISO/IEC 17065:2012.*

**BULAQUA STANDART LTD**  
CERTIFICATION BODY FOR CONSTRUCTION PRODUCTS  
“QUALITY MARK OF BWA”

1046 Sofia, 1 Hristo Smirnenski Blvd, UACEG - Rectorate, Room 115  
mobile: +359 879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)





**„БУЛАКВА СТАНДАРТ“ ЕООД**  
ОРГАН ЗА СЕРТИФИКАЦИЯ НА СТРОИТЕЛНИ ПРОДУКТИ  
„ЗНАК ЗА КАЧЕСТВО НА БАВ“

София 1046, бул. Христо Смирненски 1, УАСГ - Ректорат, ст. 115  
моб.: 0879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)

**Annex №1**

To certificate for “Quality Mark of BWA” № PL-053-085/12.02.2026

**1. Dimensions and working pressure**

№	Product	Working pressure PN, bar	Nominal size DN/OD, mm	Material	SDR
1.	Pipe	10	$16 \leq \text{DN/OD} < 75$	PE 100RC	17
2.	Pipe	10	$75 \leq \text{DN/OD} < 250$	PE 100RC	17
3.	Pipe	10	$250 \leq \text{DN/OD} < 710$	PE 100RC	17

Issuance date: 12.02.2026

Sofia

**Signature:**

Director of CBCP  
/Dipl. Ing. Alexander Marinchev/





**„БУЛАКВА СТАНДАРТ“ ЕООД**  
ОРГАН ЗА СЕРТИФИКАЦИЯ НА СТРОИТЕЛНИ ПРОДУКТИ  
„ЗНАК ЗА КАЧЕСТВО НА БАВ“

София 1046, Бул. Христо Смирненски 1, УАСГ - Ректорат, ст. 115  
моб.: 0879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)

**Annex №2**

To certificate for “Quality Mark of BWA” № PL-053-085/12.02.2026

**Evaluated characteristics in accordance with the international standards**

<b>Characteristic</b>	<b>Declaration requirement</b>
Appearance	Smooth and clean surface, without cracks and surface pores According to BDS EN 12201-2:2024, item 6.1
Colour	For water for human consumption: blue or black with blue stripes For conveying untreated water, for sewerage under pressure and drainage, vacuum sewerage systems and for water for other purposes: black or black with brown stripes According to BDS EN 12201-2:2024, item 6.2
Geometrical characteristics, mm	According to BDS EN 12201-2:2024, Tables 1 and 2
Hydrostatic strength (80 °C-1000 h)	≥ 1000h without damage According to BDS EN 12201-2:2024, Table 3
Elongation at break, %	≥ 350 % According to BDS EN 12201-2:2024, Table 3
Oxidation induction time (thermal stability), min	≥ 10 min According to BDS EN 12201-2:2024, Table 5
Melt mass-flow rate (MFR), 190 °C/ 5 kg/ 10 min	Maximum deviation ± 20 % between the measured value MFR of the raw material and the pipe According to BDS EN 12201-2:2024, Table 5
Longitudinal reversion, %	≤3,0 %, original appearance of the pipe shall remain According to BDS EN 12201-2:2024, Table 5
Resistance to SCG for PE 100-RC Strain hardening test (SHT)	Declared characteristic of raw material by manufacturer According to BDS EN 12201-1:2024, Table 1

**BULAQUA STANDART LTD**  
CERTIFICATION BODY FOR CONSTRUCTION PRODUCTS  
“QUALITY MARK OF BWA”

1046 Sofia, 1 Hristo Smirnenski Blvd, UACEG - Rectorate, Room 115  
mobile: +359 879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)





**„БУЛАКВА СТАНДАРТ“ ЕООД**  
ОРГАН ЗА СЕРТИФИКАЦИЯ НА СТРОИТЕЛНИ ПРОДУКТИ  
„ЗНАК ЗА КАЧЕСТВО НА БАВ“

София 1046, бул. Христо Смирненски 1, УАСГ - Ректорат, ст. 115  
моб.: 0879 52 50 51 office@bulaqua-standart.com  
[www.bulaqua-standart.com](http://www.bulaqua-standart.com)

Resistance to SCG for PE 100-RC Accelerated notched pipe test (ANPT)	Declared characteristic of raw material by manufacturer According to BDS EN 12201-1:2024, Table 1
Resistance to SCG for PE 100-RC Cracked round bar test (CRB)	Declared characteristic of raw material by manufacturer According to BDS EN 12201-1:2024, Table 1

Issuance date: 12.02.2026

Sofia

Signature:

Director of CBCP

/Dipl. Ing. Alexander Marinchev/



**BULAQUA STANDART LTD**  
CERTIFICATION BODY FOR CONSTRUCTION PRODUCTS  
"QUALITY MARK OF BWA"

1046 Sofia, 1 Hristo Smirnenski Blvd, UACEG - Rectorate, Room 115  
mobile: +359 879 52 50 51 office@bulaqua-standart.com

[www.bulaqua-standart.com](http://www.bulaqua-standart.com)

